

Zip Aquapoint



This unvented water heater range comes in a variety of capacities and offers over-sink or under-sink installation. Suitable for single or multiple outlets, Aquapoint 3 is glass-lined and features external temperature control and frost protection.



| MODEL | ENERGY EFFICIENCY CLASS (ERP) | *DIMENSIONS W X D X H | NOMINAL POWER RATING KW | RE-HEAT TIME (HH:MM) | CAPACITY (LITRES) |
|--------|-------------------------------|-----------------------|-------------------------|----------------------|-------------------|
| AP3/10 | A | 350mm x 265mm x 480mm | 2 kW @ 230V AC | 00:20 | 9.9 |

Features and benefits

Glass lined steel inner container

Tested to 13 bar

Sacrificial anode

For protection against corrosion

Approvals

WRAS approval and CE endorsed

Insulation

High performance foam

External temperature control

Can be replaced without draining



Product detail

Specification type

| | |
|-------------------------|--|
| Product code | AP3/10 |
| Product name | Aquapoint 3 Unvented 10 Litre Underbasin |
| Energy Efficiency Class | A |
| WRAS Approval | Yes |
| Wras Number | 2209008 |

Capacity, weights & dimensions

| | |
|--------------------------------|-----------------|
| Capacity (Litres) | 9.9 L |
| Unit dimensions (W x D x H) mm | 350 x 265 x 480 |
| Empty weight | 8.5kg |
| Filled weight | 18.5kg |

Electrical

| | |
|-----------------------|----------------|
| Nominal power rating | 2 kW @ 230V AC |
| Nominal power supply | 230V |
| Nominal rated current | 8.7 amps |
| IP rating | 24 |

Plumbing

| | |
|-------------------------------|----------|
| Wholesome water supply | Yes |
| Wholesome connection size | 1/2" BSP |
| Minimum supply water pressure | 0.1bar |
| Maximum supply water pressure | 5.5bar |

The minimum water pressure will vary if a limescale filter is installed. Please contact us to discuss your requirements.



The Zip Aquapoint III must be installed in accordance with the installation instructions and all current legislation, codes of practice and regulations governing the installation of unvented hot water cylinders in force at the time of installation. The appliance must be permanently connected to the supply through an isolating switch with a contact separation of at least 3mm in all poles and be protected by a suitably rated RCD to protect the appliance, an MCB (miniature circuit breaker) or fuse must be fitted with a rating suitable for the nominal current of the appliance.

